DEBBY RANSOM, R.N., R.H.I.T - Chief BUREAU OF FACILITY STANDARDS 3232 Elder Street P.O. Box 83720 Boise, Idaho 83720-0036 PHONE: (208) 334-6626 FAX: (208) 364-1888 E-mail: sb@dhw.idaho.gov

February 17, 2010

Kathy Prophet, Administrator Preferred Community Homes-- Cougar Creek 7091 West Emerald Street Boise, Idaho 83704

RE: Preferred Community Homes - Cougar Creek, Provider ID# 13G037

Dear Ms. Prophet:

This is to advise you of the findings of the Medicaid/Licensure Fire Life Safety Survey, which was concluded at Preferred Community Homes-- Cougar Creek, on February 8, 2010.

Enclosed is your copy of a Statement of Deficiencies/Plan of Correction, form CMS-2567, which states that no Medicaid deficiencies were noted at the time of the survey. Also, enclosed is a similar form stating that no State licensure deficiencies were noted at the time of the survey.

Thank you for the courtesies extended to us during our visit. If we can be of any help to you, please call our office at (208)334-6626.

Sincerely.

Health Facility Surveyor

Facility Fire Safety and Construction Program

TM/lj

Enclosure

DEPARTMENT OF HEALTH AND HUMAN SERVICES

Printed: 02/11/2010 FORM APPROVED

CENTERS FOR MEDICARE & MEDICAID SERVICES OMB_NO. 0938-0391 (X2) MULTIPLE CONSTRUCTION STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X3) DATE SURVEY AND PLAN OF CORRECTION IDENTIFICATION NUMBER: COMPLETED A. BUILDING 02 B. WING_ 13G037 02/08/2010 STREET ADDRESS, CITY, STATE, ZIP CODE NAME OF PROVIDER OR SUPPLIER 1230 E. COUGAR CREEK PREFERRED COMMUNITY HOMES - COUGAR MERIDIAN, ID 83642 (X5) COMPLETION (X4) ID SUMMARY STATEMENT OF DEFICIENCIES ID PROVIDER'S PLAN OF CORRECTION (EACH DEFICIENCY MUST BE PRECEEDED BY FULL (EACH CORRECTIVE ACTION SHOULD BE PRFFIX PREFIX DATE CROSS-REFERENCED TO THE APPROPRIATE REGULATORY OR LSC IDENTIFYING INFORMATION) TAG TAG DEFICIENCY) K 000 INITIAL COMMENTS K 000 The facility is a single story, Type V(000), residential building. The building is protected throughout except in the garage and attic by a NFPA 13 D fire sprinkler system with quick response sprinkler heads. There is a complete fire alarm/smoke detection system. The facility was built in January of 1996. Currently it is licensed for 8 ICF/MR beds.

The Survey was conducted by:

with 42 CFR 483.470 (j).

The facility was found to be in substantial compliance with applicable fire/life safety requirements during the annual Fire/Life Safety survey conducted on February 8, 2010. The facility was surveyed under the LIFE SAFETY CODE, 2000 Edition, Chapter 33, Existing Residential Board & Care Occupancies,

Impractical Evacuation Capability in accordance

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Tom Mroz CFI-II Health Facility Surveyor Fire/Life Safety and Construction

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

TITLE

PRINTED: 02/11/2010 FORM APPROVED

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION

(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:

(X2) MULTIPLE CONSTRUCTION

(X3) DATE SURVEY COMPLETED

13G037

A. BUILDING B. WING __

02/08/2010

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

PREFERRED COMMUNITY HOMES - COUGAR CRE 1230 E. COUGAR CREEK

X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLET DATE
M 000	16.03.11 Inital Comments	M 000		
	The facility is a single story, Type V(000), residential building. The building is protected throughout except in the garage and attic by a NFPA 13 D fire sprinkler system with quick response sprinkler heads. There is a complete fire alarm/smoke detection system. The facility was built in January of 1996. Currently it is licensed for 8 ICF/MR beds. The facility was found to be in substantial compliance with applicable fire/life safety requirements during the annual Fire/Life Safety survey conducted on February 8, 2010. The facility was surveyed in accordance with IDAPA 16.03.11			
	The Survey was conducted by:	and the state of t		and de Calcino
	Tom Mroz CFI-II Health Facility Surveyor Fire/Life Safety and Construction			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

DXZ121

(X6) DATE